



Stormwater Infiltration Feature Inspection Form

OFFICE USE ONLY
SWP _____

Submit this form by June 1st each year

Submit via email:

stormwater@arroyogrande.org

Submit by mail:

Attn: City Engineer, Community Development
300 East Branch St
Arroyo Grande, CA 93420

Inspection Details:	Inspection Date:	Inspector Name:	
	BMP# Inspected:		
	BMP Type: <input type="checkbox"/> Dry Basin <input type="checkbox"/> Infiltration Feature/Basin		
	Inspection Type: <input type="checkbox"/> Pre-Rain <input type="checkbox"/> Monthly <input type="checkbox"/> Semi-Annually <input type="checkbox"/> Annually		
Infiltration Rate:	<input type="checkbox"/> No standing water visible 24-hours following 0.50" storm event.	<input type="checkbox"/> No standing water visible 72 hours following 0.50" storm event.	<input type="checkbox"/> Standing water present longer than 72 hours following 0.50" storm event.
Visual Assessment of Inlets and Outlets:	<input type="checkbox"/> Clear of sediment and debris, no obstructions. No maintenance needed.	<input type="checkbox"/> Some accumulation of sediment or debris, minor maintenance needed.	<input type="checkbox"/> Significant blockage with sediment and debris. Maintenance required.
Sediment or Particle Accumulation	<input type="checkbox"/> Sediment/particulate accumulation less than 1.0". No impacts to infiltration.	<input type="checkbox"/> Sediment/particulate accumulation less than 2.0".	<input type="checkbox"/> Sediment/particulate accumulation greater than 2.0". Cleanout is required.
Surface Layer Condition	<input type="checkbox"/> No visible loss of cover/infiltration media (rocks, gravel, etc.). No rill erosion or scour observed around cover media.	<input type="checkbox"/> Cover media requires infill or repair or minor erosion is visible around media.	<input type="checkbox"/> Cover media (rock, gravel, etc.) requires replacement or repair. Rill erosion evident in BMP. Maintenance required.
Debris or Litter:	<input type="checkbox"/> No debris, litter, or evidence of illicit dumping.	<input type="checkbox"/> Small amount of debris, litter. Debris and litter removed at the time of inspection.	<input type="checkbox"/> Debris and litter present in significant quantities. Evidence of illicit dumping. Removal or repair required.



CITY OF ARROYO GRANDE
COMMUNITY DEVELOPMENT DEPARTMENT
**Stormwater Infiltration Feature
Inspection Form**

OFFICE USE ONLY SWP _____

Maintenance Records:	Have any maintenance needs identified by this inspection been scheduled for repair? <input type="checkbox"/> YES <input type="checkbox"/> NO	Date that maintenance will be completed:
-----------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------

Notes:

Photographs taken? <input type="checkbox"/> YES <input type="checkbox"/> NO	Photographs submitted? <input type="checkbox"/> YES <input type="checkbox"/> NO
------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------

Please label/name photos with the BMP number for the photographed stormwater feature. Submission of photos is highly encouraged.

<i>For City Use Only</i>		
<i>Date Received:</i>	<i>Staff Reviewer:</i>	<i>SWP Case #:</i>