



CITY OF ARROYO GRANDE
 COMMUNITY DEVELOPMENT DEPARTMENT
**Stormwater Detention Feature
 Inspection Form**

OFFICE USE ONLY
 SWP _____

Submit this form by June 1st each year

Submit via email:

stormwater@arroyogrande.org

Submit by mail:

Attn: City Engineer, Community Development
 300 East Branch St
 Arroyo Grande, CA 93420

Inspection Details:	Inspection Date:		Inspector Name:		
	BMP# Inspected:				
	Structural BMP Type:		Detention Basin	Settling Basin	
	Inspection Type:	Pre-Rain	Monthly	Semi-Annually	Annually
Vegetation Cover Condition:	<input type="checkbox"/> Vegetation healthy (if present). No potential flood hazards or fire hazards from dead vegetation or overgrowth.	<input type="checkbox"/> Moderate overgrowth or vegetation death. Mowing or trimming necessary to maintain capacity and flow paths.	<input type="checkbox"/> Vegetation overgrowth presents hazards to inflows, outflows, and retention. Maintenance required immediately.		
Visual Assessment of Inlets and Outlets:	<input type="checkbox"/> Inlets and outlets fully stabilized, no signs of surface erosion or scour. No repair necessary.	<input type="checkbox"/> Inlets/outlets require minor repair of retrofit to control surface erosion or scour.	<input type="checkbox"/> Inlets/outlets show signs of erosion or scour more than 2". Repair required immediately.		
Sediment or Particle Accumulation:	<input type="checkbox"/> No evidence of particle accumulation at base. No impacts to outflow.	<input type="checkbox"/> Sediment/particulate accumulation less than 15% of basin depth. No impacts to outflow.	<input type="checkbox"/> Sediment/particulate accumulation greater than 25% of basin depth. Feature requires maintenance to remove settled particulates.		
Sidewalls Condition:	<input type="checkbox"/> No evidence of erosion, rodent holes or compromise.	<input type="checkbox"/> Minor damage due to erosion or rodent holes. Sidewalls require repair.	<input type="checkbox"/> Evidence of piping through sidewalls due to rodent holes or erosion damage. Immediate repair required.		
Presence of Debris or Illicit Activity:	<input type="checkbox"/> No debris, litter, or evidence of illicit dumping. Perimeter fence or control is secure (if present).	<input type="checkbox"/> Small amount of debris or litter. Perimeter fence or control is secure (if present). Debris and litter removed at time of inspection.	<input type="checkbox"/> Debris and litter present in significant quantities. Evidence of illicit dumping. Perimeter fence or control needed or requires repair.		



CITY OF ARROYO GRANDE
COMMUNITY DEVELOPMENT DEPARTMENT
**Stormwater Detention Feature
Inspection Form**

OFFICE USE ONLY
SWP _____

Maintenance Records:	Have maintenance needs identified by this inspection been scheduled for repair? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Date that maintenance will be completed:</i>
-----------------------------	---

Notes:

Photographs taken? <input type="checkbox"/> YES <input type="checkbox"/> NO	Photographs submitted? <input type="checkbox"/> YES <input type="checkbox"/> NO
--	--

Please label/name photos with the BMP number for the photographed stormwater feature. Submission of photos is highly encouraged.

For City use only:

Date Received:	Staff Reviewer:	SWP Case #:
-----------------------	------------------------	--------------------