



Vegetated Stormwater Feature Inspection Form

OFFICE USE ONLY

SWP _____

Submit this form by June 1st each year

Submit via email:

stormwater@arroyogrande.org

Submit by mail:

Attn: City Engineer, Community Development
300 East Branch St
Arroyo Grande, CA 93420

Inspection Details:	Inspection Date:	Inspector Name:		
	BMP# Inspected:			
	Structural BMP Type: <input type="checkbox"/>	Biofiltration Feature <input type="checkbox"/>	Bioretention Feature <input type="checkbox"/>	<input type="checkbox"/> Bioswale <input type="checkbox"/> Wet Basin
	Inspection Type: <input type="checkbox"/> Pre-Rain <input type="checkbox"/> Monthly <input type="checkbox"/> Semi-Annually <input type="checkbox"/> Annually			
Overall Feature Condition:	<input type="checkbox"/> Vegetation is healthy, no litter or debris observed.	<input type="checkbox"/> Vegetation requires maintenance (weed removal, trimming, or replacement). Some litter present.	<input type="checkbox"/> Significant vegetation maintenance and litter removal necessary. Maintenance required to maintain BMP functionality.	
Visual Assessment of Inlets and Outlets:	<input type="checkbox"/> Drain inlets and outlets are clear of sediment and debris, no maintenance required.	<input type="checkbox"/> Some accumulation of sediment and debris, minor maintenance needed.	<input type="checkbox"/> Significant blockage with sediment and debris. Maintenance required.	
Sediment or Particle Accumulation:	<input type="checkbox"/> Sediment/particulate accumulation less than 1.0" throughout feature.	<input type="checkbox"/> Sediment/particulate accumulation 1.0 – 3.0" throughout feature. Functionality is not impaired.	<input type="checkbox"/> Sediment covers vegetation greater than 3.0" in any location. Maintenance required.	
Evidence of Erosion:	<input type="checkbox"/> No visible loss of specialized soil media. No rill erosion or scour observed.	<input type="checkbox"/> Soil media requires infill/repair. Minor erosion visible.	<input type="checkbox"/> Soil media significantly impacted. Rill erosion evident in BMP. Maintenance required.	
Drainage Condition:	<input type="checkbox"/> No standing water visible 24-hours following 0.50" storm event.	<input type="checkbox"/> No standing water visible 72 hours following 0.50" storm event.	<input type="checkbox"/> Standing water present longer than 72 hours following 0.50" storm event.	
<input type="checkbox"/> Not observed.				



CITY OF ARROYO GRANDE
COMMUNITY DEVELOPMENT DEPARTMENT
**Vegetated Stormwater Feature
Inspection Form**

OFFICE USE ONLY

SWP _____

Vegetation Cover:	<input type="checkbox"/> 75-100% of vegetation is healthy. Minimal weeds present. Vegetation is maintained at specific height.	<input type="checkbox"/> 50-75% of vegetation is healthy. Some weeds present. Vegetation may need to be trimmed.	<input type="checkbox"/> 50% or less of original vegetation cover remains. Weeds or bare soil present.
Date that maintenance will be completed:			
Additional Notes:			
Photographs taken? <input type="checkbox"/> Yes <input type="checkbox"/> No		Photographs submitted? <input type="checkbox"/> Yes <input type="checkbox"/> No	
If submitting photos via email, please label/name the photo with the BMP number for the photographed stormwater feature. Submission of photos is optional, but encouraged.			
For City Use Only:			
Date Received:	Staff Reviewer:	SWP Case #:	