



CITY OF ARROYO GRANDE  
 COMMUNITY DEVELOPMENT DEPARTMENT  
**Vegetated Stormwater Feature  
 Inspection Form**

OFFICE USE ONLY  
 SWP \_\_\_\_\_

<b>Submit this form by June 1<sup>st</sup> each year</b>				
<b>Submit via email:</b> <a href="mailto:stormwater@arroyogrande.org">stormwater@arroyogrande.org</a>		<b>Submit by mail:</b> Attn: City Engineer, Community Development 300 East Branch St Arroyo Grande, CA 93420		
<b>Inspection Details:</b>	Inspection Date:		Inspector Name:	
	BMP# Inspected:			
	Structural BMP Type: <input type="checkbox"/>	Biofiltration Feature <input type="checkbox"/>	Bioretention Feature <input type="checkbox"/>	Bioswale <input type="checkbox"/> Wet Basin <input type="checkbox"/>
	Inspection Type: <input type="checkbox"/> Pre-Rain <input type="checkbox"/> Monthly <input type="checkbox"/> Semi-Annually <input type="checkbox"/> Annually			
<b>Overall Feature Condition:</b>	<input type="checkbox"/> Vegetation is healthy, no litter or debris observed.	<input type="checkbox"/> Vegetation requires maintenance (weed removal, trimming, or replacement). Some litter present.	<input type="checkbox"/> Significant vegetation maintenance and litter removal necessary. Maintenance required to maintain BMP functionality.	
<b>Visual Assessment of Inlets and Outlets:</b>	<input type="checkbox"/> Drain inlets and outlets are clear of sediment and debris, no maintenance required.	<input type="checkbox"/> Some accumulation of sediment and debris, minor maintenance needed.	<input type="checkbox"/> Significant blockage with sediment and debris. Maintenance required.	
<b>Sediment or Particle Accumulation:</b>	<input type="checkbox"/> Sediment/particulate accumulation less than 1.0" throughout feature.	<input type="checkbox"/> Sediment/particulate accumulation 1.0 – 3.0" throughout feature. Functionality is not impaired.	<input type="checkbox"/> Sediment covers vegetation greater than 3.0" in any location. Maintenance required.	
<b>Evidence of Erosion:</b>	<input type="checkbox"/> No visible loss of specialized soil media. No rill erosion or scour observed.	<input type="checkbox"/> Soil media requires infill/repair. Minor erosion visible.	<input type="checkbox"/> Soil media significantly impacted. Rill erosion evident in BMP. Maintenance required.	
<b>Drainage Condition:</b>	<input type="checkbox"/> No standing water visible 24-hours following 0.50" storm event.	<input type="checkbox"/> No standing water visible 72 hours following 0.50" storm event.	<input type="checkbox"/> Standing water present longer than 72 hours following 0.50" storm event.	
<input type="checkbox"/> Not observed.				



CITY OF ARROYO GRANDE  
COMMUNITY DEVELOPMENT DEPARTMENT  
**Vegetated Stormwater Feature  
Inspection Form**

OFFICE USE ONLY  
SWP \_\_\_\_\_

<b>Vegetation Cover:</b>	<input type="checkbox"/> 75-100% of vegetation is healthy. Minimal weeds present. Vegetation is maintained at specific height.	<input type="checkbox"/> 50-75% of vegetation is healthy. Some weeds present. Vegetation may need to be trimmed.	<input type="checkbox"/> 50% or less of original vegetation cover remains. Weeds or bare soil present.
<b>Date that maintenance will be completed:</b>			
<b>Additional Notes:</b>			
<b>Photographs taken?</b> <input type="checkbox"/> Yes <input type="checkbox"/> No		<b>Photographs submitted?</b> <input type="checkbox"/> Yes <input type="checkbox"/> No	
If submitting photos via email, please label/name the photo with the BMP number for the photographed stormwater feature. Submission of photos is optional, but encouraged.			
<b>For City Use Only:</b>			
<b>Date Received:</b>	<b>Staff Reviewer:</b>	<b>SWP Case #:</b>	